


# COLLEGE OF ENGINEERING THALASSERY

## DEPARTMENT OF ECE

### Proposed specification of the UPS

Sl. No.	Description	Rate Rs	Unit	Amount (Rs)
1.	Supply, Installation, Testing and Commissioning of 5 KVA, 48 V Sine Wave UPS with following configuration.  Input voltage : Single Phase , 230V AC- 45-55Hz,  Output waveform: True sine wave.  Output voltage : Single Phase 230V AC ,  Voltage Regulation +/-1% ,  power factor : 0.8 to Unity  Over load Capacity : 100%-125%,  Indicators : Mains on, UPS on, Battery on charge, overload etc  Battery : Tubular 100AH * 4 nos  Warranty: 2 year for UPS & 3Years for Tubular battery	120000	1	120000

  
**Principal**  
College of Engineering  
Thalassery - 670107

  
SUDHEER. V R

HOD, ECE

